



# ELTK

## CLEVERTRONICS EMERGENCY LIGHTING TEST SWITCH



PRODUCT INFORMATION	
Part Number	ELTK
MIC	AUF00600230001
Description	Emergency Lighting Test Switch
Construction	Plastic Enclosure
Mounting	Surface Mount adjacent to Switchboard
Dimensions L x W x H	160mm x 160mm x 78mm
Switch Type	Key switch operated
Contactor Type	4 Pole normally closed
Timer Configuration	Set to 4 hours discharge test time with automatic reset (can be set to a maximum of 10 hours)
Operating Temperature	0°C to 40°C
Applicable Standards	AS/NZS3820, CISPR15, AS/NZS2293.3 section 4.3.2, Manual Test Facilities
Compliance Marking (RCM)	

The product details described in this document are current as at the version date of the document. We reserve the right to change product design, specifications or materials (Specifications) as part of our continuous improvement program. Please confirm the applicable Specifications at the time of placing your order

